



City of Tacoma

ENVIRONMENTAL SERVICES DEPARTMENT

ADDENDUM NO.2

DATE: March 28, 2023

REVISIONS TO:

Request for Bids Specification No. ES23-0026F

**CENTRAL WASTEWATER TREATMENT PLANT SECONDARY CLARIFIER #5
RESTORATION**

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline has not been changed.

REVISIONS TO THE PLANS:

Change No. 1 – Revision to Sheet 9 – Section B, sheet 9 of 13

Add the following note:

3. Skirt baffle dimension - $\frac{1}{4}$ " x 4' x 6' PL Contractor to field verify before fabrication.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the proposal page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. ES23-0026F Addendum No. 1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.