



City of Tacoma

Questions and Answers 2

SW & WW MANITOU DISTRICT GREEN INFRASTRUCTURE PROJECT

RFB Specification No. **ES21-0629F**

All interested parties had the opportunity to submit questions in writing by email to Dawn DeJarlais, Senior Buyer by December 5, 2022. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities](#) / *Public Works and Improvements Solicitations*, and then click *Questions and Answers* for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: What is the roadway section on S. 66th Street? The roadway sections on sheets 41 & 42 do not seem to have the stationing where these residential roads would cross S 66th Street?

Answer 1: Available record drawings indicate that S 66th was constructed with a 3" Asphalt over 1" Crushed Stone over 6" Bankrun Ballast road section.

Question 2: Does the roadway excavation quantity provided for bid item R9 include the excavation depth required for the topsoil placement shown on City of Tacoma's standard detail GSI-01d?

Answer 2: Yes.