

CITY OF TACOMA

Environmental Services Department Science and Engineering Division

ADDENDUM NO. 2 DATE: May 3, 2022

REVISIONS TO:
Request for Rids Specification

Request for Bids Specification No. ES22-0047F South Tacoma Pump Station Rehabilitation Project Phase 1

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

None.

REVISIONS TO VOLUME 1 – GENERAL REQUIREMENTS:

None.

REVISIONS TO VOLUME 2 – TECHNICAL SPECIFICATIONS:

Change No. 1 Revision to Section 01_11_00 – SUMMARY OF WORK

REPLACE sub-paragraph 1.04.A.1 in its entirety with the following:

Approximately 70 feet of 30-inch diameter steel piping and associated couplings and fittings, including tape wrap and polyurethane lining for shop wrap/touchup.

Change No. 2 Revision to Section 01_11_00 – SUMMARY OF WORK

REPLACE sub-paragraph 1.04.A.3 in its entirety with the following:

Approximately 60 feet of 20-inch diameter steel piping and associated couplings and fittings, including tape wrap and polyurethane lining for shop wrap/touchup.

Change No. 3 Revision to Section 01_11_00 - SUMMARY OF WORK

REPLACE sub-paragraph 1.04.A.4 in its entirety with the following:

Approximately 20 feet of 14-inch diameter steel piping and associated couplings and fittings, including polyurethane lining for shop touchup.

Change No. 4 Revision to Section 40_05_06.03 – Pipe Couplings

REPLACE sub-paragraph 3.01.E.1 in its entirety with the following:

Grooved ends: type as indicated on the Drawings. Install in accordance with manufacturer's instructions.

Change No. 5 Revision to Section 40_05_24.01 – Steel Pipe: Exposed

REPLACE sub-paragraph 3.01.E in its entirety with the following:

Grooved joints:

- 1. Piping with grooved joints shall be installed where indicated on the Drawings.
- 2. Assemble in accordance with manufacturer's published instructions.
- 3. Support grooved-end pipe in accordance with manufacturer's recommendations and as shown on the Drawings.

REVISIONS TO VOLUME 3 – DRAWINGS:

Change No. 6 Revision to Drawing C03 Sheet 6:

REPLACE Key Note 2 with the following:

THE STEEL PIPE, FITTINGS, COUPLINGS, AND SST SLEEVES ARE SUPPLIED BY THE OWNER, UNLESS OTHERWISE NOTED. CONTRACTOR SHALL FIELD VERIFY DIMENSIONS AND SHOP CUT AND ROLL GROOVE PIPE PER VICTAULIC SPECIFICATIONS (WHERE NOTED) AND INSTALL. CONTRACTOR TO PROVIDE AND INSTALL CORROSION PROTECTION, BOLTS, NUTS, WASHERS, AND GASKETS FOR FLANGED CONNECTIONS, AND SHOP REPAIR DAMAGED PIPE COATINGS AND LININGS IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS WITH MATERIAL SUPPLIED BY THE OWNER. SEE SHEET CP01 FOR CORROSION PROTECTION DETAILS.

Change No. 7 Revision to Drawing C04 Sheet 7:

REPLACE General Note 2 with the following:

THE STEEL PIPE, FITTINGS, COUPLINGS, AND SST SLEEVES ARE SUPPLIED BY THE OWNER, UNLESS OTHERWISE NOTED. CONTRACTOR SHALL FIELD VERIFY DIMENSIONS AND SHOP CUT AND ROLL GROOVE PIPE PER VICTAULIC SPECIFICATIONS (WHERE NOTED) AND INSTALL. CONTRACTOR TO PROVIDE AND INSTALL CORROSION PROTECTION, BOLTS, NUTS, WASHERS, AND GASKETS FOR FLANGED CONNECTIONS, AND SHOP REPAIR DAMAGED PIPE COATINGS AND LININGS IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS WITH MATERIAL SUPPLIED BY THE OWNER. SEE SHEET CP01 FOR CORROSION PROTECTION DETAILS.

Change No. 8 Revision to Drawing C04 Sheet 7:

REPLACE Key Note 1 with the following:

10'-0" LONG PLAIN END X GROOVED END SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT AND ROLL GROOVE PLAIN END TO MATCH FINAL PIPING LAYOUT.

Change No. 9 Revision to Drawing C04 Sheet 7:

REPLACE Key Note 7 with the following:

12'-0" LONG PLAIN END X GROOVED END SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT AND ROLL GROOVE PLAIN END PER FLANGE ADAPTER TO MATCH FINAL PIPING LAYOUT.

Change No. 10 Revision to Drawing C04 Sheet 7:

REPLACE Key Note 8 with the following:

8'-0" LONG PLAIN END X GROOVED END SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT AND ROLL GROOVE PLAIN END TO MATCH FINAL PIPING LAYOUT.

Change No. 11 Revision to Drawing C04 Sheet 7:

REPLACE Key Note 9 with the following:

20'-0" LONG PLAIN END X GROOVED END SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT AND ROLL GROOVE PLAIN END TO MATCH FINAL PIPING LAYOUT.

Change No. 12 Revision to Drawing C04 Sheet 7:

REPLACE Key Note 10 with the following:

25'-0" LONG PLAIN END X GROOVED END SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT AND ROLL GROOVE PLAIN END TO MATCH FINAL PIPING LAYOUT.

Change No. 13 Revision to Drawing M02 Sheet 20:

REPLACE General Note 2 with the following:

THE STEEL PIPE, FITTINGS, COUPLINGS, AND FLOWMETER ARE SUPPLIED BY THE OWNER, UNLESS OTHERWISE NOTED. CONTRACTOR SHALL FIELD VERIFY DIMENSIONS AND SHOP CUT AND ROLL GROOVE PIPE PER VICTAULIC SPECIFICATIONS (WHERE NOTED) AND INSTALL. CONTRACTOR TO PROVIDE AND INSTALL CORROSION PROTECTION, BOLTS, NUTS, WASHERS, AND GASKETS FOR FLANGED CONNECTIONS, AND SHOP REPAIR DAMAGED PIPE COATINGS AND LININGS IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS WITH MATERIAL SUPPLIED BY THE OWNER. SEE SHEET CP01 FOR CORROSION PROTECTION DETAILS.

Change No. 14 Revision to Drawing M02 Sheet 20:

REPLACE Steel Pipe Specifications Note 2 with the following:

CONTRACTOR TO FIELD COAT EXPOSED STEEL PIPE, FITTINGS, AND COUPLINGS FOLLOWING INSTALLATION. SHOP REPAIR DAMAGED LINING AND COATINGS IN STRICT ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS WITH MATERIAL SUPPLIED BY THE OWNER. SHOP GROOVING SHALL BE AGS ROLL GROOVE PER VICTAULIC SPECIFICATIONS.

Change No. 15 Revision to Drawing M02 Sheet 20:

REPLACE Key Note 2 with the following:

4'-0" LONG PLAIN END X PLAIN END STEEL SPOOL. CONTRACTOR TO FIELD VERIFY DIMENSION AND SHOP CUT TO MATCH FINAL PIPING LAYOUT.

Change No. 16 Revision to Drawing M02 Sheet 20:

REPLACE Key Note 4 with the following:

STEEL PIPE/FITTINGS. CONTRACTOR TO INSTALL.

Change No. 17 Revision to Drawing M02 Sheet 20:

DELETE 1'-6" dimension from face of wall to face of flowmeter flange on 30" RS piping in Section A.

REVISIONS TO VOLUME 4 – REFERENCE DOCUMENTS:

None.

REVISIONS TO THE BID SUBMITTAL PACKAGE:

None.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the Signature Page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. ES22-0047F Addendum No. 2. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Lance Bunch, ESSE