



CITY OF TACOMA

Tacoma Power / Transmission and Distribution

ADDENDUM NO. 1

DATE: October 4, 2021

REVISIONS TO:

**Request for Bids Specification No. PT21-0543F
15kV Vault and Network Style Transformers**

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline remains the same.

REVISIONS TO THE PROPOSAL PAGES:

Per Section 1.08.1B, required values have been revised to remove "Diameter" and replace with "Width" and "Length".

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PT21-0543F Addendum No. 1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Joe Parris, Tacoma Power Transmission and Distribution

Material Specification PT21-0543F
15kV Vault and Network Style Transformers

PROPOSAL PRICING SHEETS – LOW PROFILE VAULT STYLE
ESTER OIL FILLED 12470 GRDY PRIMARY 3-PHASE

Item	MID #	kVA	Secondary Voltage	Est. Qty 3 Years	Unit Price	Total Price FOB Destination (Quantity x Unit Price)
1	46669	500	208/120	6	\$	\$
2	46702	1000	208/120	10	\$	\$
3	46700	500	480/277	3	\$	\$
4	46703	1000	480/277	3	\$	\$
5	46704	1500	480/277	2	\$	\$
Sub-Total						\$

Item	kVA	Height (in.)	Width (in.)	Length (in.)	Weight Incl. Oil (lb.)	Gallons of Oil	%Z	Represented Efficiency per DOE 10 CFR Part 431
1	500						%	%
2	1000						%	%
3	500						%	%
4	1000						%	%
5	1500						%	%

PROPOSAL PRICING SHEETS – STANDARD VAULT STYLE
ESTER OIL FILLED 12470 GRNDY PRIMARY 3-PHASE

Item	MID #	kVA	Secondary Voltage	Est. Qty 3 Years	Unit Price	Total Price FOB Destination (Quantity x Unit Price)
6	46668	500	208/120	2	\$	\$
7	40627	1000	208/120	2	\$	\$
8	TBD	500	480/277	2	\$	\$
9	35638	1000	480/277	2	\$	\$
10	35689	1500	480/277	2		
Sub-Total						\$

Item	kVA	Height (in.)	Width (in.)	Length (in.)	Weight Incl. Oil (lb.)	Gallons of Oil	%Z	Represented Efficiency per DOE 10 CFR Part 431
1	500						%	%
2	1000						%	%
3	500						%	%
4	1000						%	%
5	1500						%	%

PROPOSAL PRICING SHEETS – NETWORK VAULT STYLE
ESTER OIL FILLED 12470 GRNDY PRIMARY 3-PHASE

Item	MID #	kVA	Secondary Voltage	Est. Qty 3 Years	Unit Price	Total Price FOB Destination (Quantity x Unit Price)
11	35771	500	216/125	4	\$	\$
12	35881	750	216/125	21	\$	\$
13	35635	1000	216/125	2	\$	\$
14	35636	750	480/277	4	\$	\$
15	35687	1000	480/277	2	\$	\$
16	TBD	1500	480/277	2	\$	\$
Sub-Total						\$

Item	kVA	Height (in.)	Width (in.)	Length (in.)	Weight Incl. Oil (lb.)	Gallons of Oil	%Z	Represented Efficiency per DOE 10 CFR Part 431
1	500						%	%
2	1000						%	%
3	500						%	%
4	1000						%	%
5	1500						%	%

Material Specification PT21-0543F 15kV Vault and Network Style Transformers

indicating new higher/lower price in effect and/or for raw materials used in the manufacturing of the equipment/material. The City reserves the right to accept or reject all such increases/decreases.

1.06.5 - PROMOTIONAL PRICING

City is entitled to any promotional pricing during contract period that is lower than the Supplier's pricing as provided in bid. This promotional pricing shall include, but not be limited to: sale prices, price lowering, and/or lump-sum rebates.

1.07 - PERFORMANCE BOND/BID BOND

The Performance and Bid Bonds have been waived for this contract.

1.08 - RESPONDENT'S PROPOSAL

1.08.1 - RESPONDENT REQUIREMENTS

Submittals must be emailed with the Specification number, Specification title, and Respondent name in the subject line, and received by the City of Tacoma Purchasing Division by the date and time specified in the Request for Bids page or subsequent addenda.

The bid package submitted must be returned with the Respondent's proposal filled in as directed, including all data requested by the Provisions of these Specifications. All blank spaces on the Proposal forms will be properly filled in, printed in ink or typewritten.

1.08.1A - SIGNATURE PAGE

The "Signature Page" included with the original submittal shall be **signed** by the responsible company official and include printed or typewritten designation of the office they hold in the company.

1.08.1B - PROPOSAL SHEET DATA REQUIREMENTS

The Proposal Pricing Sheets request the following information to be included with the Respondent's submittal. Submittals that do not include the requested information may be considered non-responsive.

Required Values	Specific Requirement
Height (in.)	The height of a typical unit in inches
Width (in.)	The width of a typical unit in inches
Lenth (in.)	The length of a typical unit in inches
Weight Including Oil (lbs)	The weight of a typical unit in pounds.
Oil Capacity (gal.)	The quantity of oil in a typical unit in gallons.
Impedance	Measured at 85°C per IEEE C57.12.00.
Represented Efficiency	The represented transformer efficiency certified by the manufacturer per DOE 10 CFR Part 431

^[1] Each individual unit shipped to the City shall be less than or equal to these quoted maximum guaranteed losses or may be returned to the factory for replacement at the manufacturer's expense.