



CITY OF TACOMA

Tacoma Public Utilities / Transmission and Distribution

ADDENDUM NO. 02

DATE: February 1, 2022

REVISIONS TO:

**Request for Bids Specification No. PT21-0680F
Led Luminaires and Accessories**

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline remains the same.

REVISIONS TO THE TECHNICAL PROVISIONS:

Section 2.08 – Approved Manufacturers: EvLuma catalog number revised from “AM-70-5-V-D-P-STD-10” to “AX-70-30-5-C-P-STD-10”.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PT21-0680F Addendum No. 2. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Joe Parris, Management Analyst III

2.07 – CONSTRUCTION

| Description | Bid Item #1 |
|----------------------------------|--------------------------------------------------------------------------------|
| Housing construction | Cast aluminum housing with integral heat sink |
| Finish | Gray powder coat |
| Mounting | Accepts 1-1/4" or 1" arm Adjustable angle +/- 5% |
| 3G Vibration withstand | ANSI C136.31-2010 Luminaire Vibration - Level 2 Bridge/Overpass |
| Ease of Installation/Maintenance | Tool-less access panel 66" pigtails standard or 10', 20' or none as options |
| Optical Lens | Diffused textured glass to reduce glare |
| Photo control | UV-stabilized polycarbonate housing |
| Shield | Optional three position (including backlight) field-installable shield |
| Single unit net weight | < 10 lbs |

2.08 – APPROVED MANUFACTURERS

The following manufacturers have been approved for supply of LED Luminaires and Accessories intended for Tacoma Power's off-street lighting program:

| Item # | Item Description | MFG | Catalog Number |
|---------------|----------------------------------------|------------|----------------------------------------------------------|
| 1 | LUMINAIRE,LED,70W, DOMED LENS,W/EYE | EvLuma | AM-70-5-V-D-P-STD-10 AX-70-30-5-C-P-STD-10 |
| 2 | SHIELD,LUMINAIRE,LED | EvLuma | LTS |