



**CITY OF TACOMA**  
**Public Works Engineering Division**

**ADDENDUM NO. 2**

**DATE: 3/11/2021**

**REVISIONS TO:**

**Request for Bids Specification No. PW20-0071F**

**56TH ST AND CIRQUE DRIVE CORRIDOR IMPROVEMENTS PHASE 2**

**NOTICE TO ALL BIDDERS:**

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

**REVISIONS TO THE SUBMITTAL DEADLINE:**

The submittal deadline has changed to **11:00 a.m., Pacific Time Tuesday, March 30, 2021.**

**QUESTIONS AND ANSWERS:**

**Question 1: BID ITEM #R62; Signal Modifications @ 56th & S. Washington St– Plan sheet 85 – No signal detail provided. Construction notes call for some of the new peds to be installed with new clamshell mounts while others on existing mounts. Please confirm we are to use existing mounts as called for and not provide all new peds with clamshell mounts?**

**Answer 1:** Revised plan to be provided.

**Question 2: BID ITEM #63; Signal Modifications @ 56th & S. Puget Sound Ave– No signal plan sheets for this location. Will there be an addendum providing plan sheets for the signal modification bid item?**

**Answer 2:** Revised plan sheets to be provided.

**Question 3: BID ITEM #64; Signal Modifications @ 56th & S. Cedar Plan Sheet 87 - Construction notes call for some of the new peds to be installed with new clamshell mounts while others on existing mounts. Please confirm we are to use existing mounts as called for and not provide all new peds with clamshell mounts.**

**Answer 3:** As noted in the plans, Pole 1 and 4 are designed to get new clamshell mounts and poles 2 and 3 will reuse the existing pedestrian signal mounts.

**Question 4: BID ITEM #R67; Signal Modification @ 54th & S. Oakes - No signal plan sheets for this location. Will there be an addendum providing plan sheets for the signal modification bid item?**

**Answer 4:** Revised plan sheets to be provided.

**Question 5: BID ITEM #R68; Signal Modification @ 54th & S. Tacoma Way - No signal plan sheets for this location. Will there be an addendum providing plan sheets for the signal modification bid item?**

Answer 5: Revised plan sheets to be provided.

**Question 6: Wire Note 2 on Sheet 93 is on the SE Corner of the intersection. It is shown leaving that corner, heading east on S 47th St but it does not show where it terminates and I cannot find it anywhere else on the project. Please advise as to where this conduit terminates.**

Answer 6: See continuation with note 2 on sheet 94. Conduit terminates in junction box at STA 13+00.

**Question 7: There are no wire schedule and construction notes do not match with the drawings on sheet 85. Southwest corner of the Washington st and S 56th St intersection, a junction box has a construction note of a ppb post. Construction note 12 says PPB curb post and does not include a ped head as shown on plans on the same corner.**

Answer 7: Revised plan to be provided.

**Question 8: Can you tell me if the detail attached is what is intended for contractors to provide for bid item #R20 Commercial Storm Drain on the 56th Street and Cirque Drive project bidding on 3.2?**

Answer 8: Yes, the Commercial Storm Drain shall be constructed per City of Tacoma Standard Plan SU-29.

**Question 9: Regarding bid item #R20 COMMERCIAL STORM DRAINS - Does that bid item consist of a thru curb inlet catch basin with a frame,grate and hood? Or is that similar to City of Tacoma detail RU29?**

Answer 9: Commercial Storm Drains shall be constructed per City of Tacoma Standard Plan SU-29.

**Question 10: In reviewing the Plans and City Standard Plans, I'm seeing some convoluted details in regards to the size of the Plastic ONLY Symbols as well as the Plastic Sharrow Symbols, Can you please clarify which ones will be required as it is all specified as Type B Preformed Material it will have to be ordered via a supplier that is on the East Coast. Please Advise.**

Answer 10: Dimensions for height and spacing for the plastic ONLY letter markings shall follow the details on plan sheet 74. All other details for the plastic ONLY letter markings shall follow City Standard Plans. Details and notes provided on plan sheet 75 should be followed for the plastic Sharrow symbols used in the project. City Standard Plan CH-11 can still be referenced for general layout guidance and more intricate layout details as conformed to the depictions/sizes shown on plan sheet 75. Delete any headers that are not used. Consult with your purchasing analyst or assistant before revising the headers below.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PW20-0071F Addendum No. 2. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Basel Kitmitto, Public Works Engineering