



City of Tacoma

Questions and Answers

15th Street Transient Moorage Dock Replacement RFB Specification No. PW22-0059F

All interested parties had the opportunity to submit questions in writing by email to Doreen Klaaskate, Senior Buyer. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities](#) / *Public Works and Improvements Solicitations*, and then click *Questions and Answers* for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: Do state tax rule 170 or 171 apply to the project? If they applied differently to different bit items please provide break down for each bid item.

Answer 1: This project is located within the City of Tacoma rights of way therefore a line item for sales tax isn't applicable.

Question 2: Is the \$600,000 estimate includes or excludes tax.

Answer 2: Includes all tax.

Question 3: Per section 6. Wave load it states the quartering seas wavelength as 43 feet with at 2.4 seconds. When you apply the wavelength equation of $5.12 \cdot t^2$ you get a wavelength of 30 feet. Please confirm the wavelength for the quartering seas.

Answer 3: For quartering seas, the period shall be taken as 2.9 seconds.