



City of Tacoma

Tacoma Water

ADDENDUM NO. 2

DATE: 3/14/23

REVISIONS TO:

Request for Bids Specification No. TW22-0399F

Pulling and Cleanout of South Tacoma Wells – Phase I (Re-Bid)

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline remains the same.

REVISIONS TO THE GENERAL INFORMATION AND REQUIREMENTS:

Revise the additional information on the Request for Bids page to read Requests for information regarding the specifications may be obtained by contacting Brandon Snow, Senior Buyer by email to bsnow@cityoftacoma.org.

REVISIONS TO THE TECHNICAL PROVISIONS:

Add to the Technical Provisions, Section 19.5.1.1, Owner's Subcontractors, at the end of the second paragraph:

The owner uses Byron Jackson equipment as the standard manufacturer for its submersible pumps and motors due to the low revolutions per minute and especially long life, as well as the ability to repair or rebuild rather than replace existing equipment in some cases.

Add to the Technical Provisions, Section 19.5.3, Cleanout, as the last paragraph:

As an alternative to a cable tool rig, a properly sized and properly equipped pump hoist may be acceptable if it is functionally equivalent to a Bucyrus Erie 22W or Speedstar 71. Performance will be evaluated, and ineffective or inadequate equipment or operation is grounds for non-payment or contract termination. Given the diameter of these wells, pump hoists must be capable of operating a reasonably sized sand-pump bailer (8" minimum) and swabs of a sufficient size and weight to be effective in large-diameter wells. A minimum of 75 pounds of tooling weight per inch of well screen inside diameter is required for effective surging. Surging rate and stroke should be adjustable, with a capability of not less than 30 2-foot strokes per minute. The hoist and sandline must provide ample capacity for easily lifting the tools as well as energizing the column of water above them during surging.



City of Tacoma

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid may contact the Purchasing Division at 253-502-8468 and request return of their bid for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. TW22-0399F Addendum No.2. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Jason Moline, P.E., Tacoma Water