



CITY OF TACOMA

Tacoma Water

ADDENDUM NO. 1

DATE: March 2, 2023

REVISIONS TO:

Request for Bids Specification No.

TW23-0025N Portland Avenue Isolation

Valve

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline remains the same.

REVISIONS TO THE TECHNICAL REQUIREMENTS:

1. Replace paragraph 18.8.2 of paragraph 18.8 – Metal-Seated Ball Valves of Section 40 05 63 METAL-SEATED BALL VALVES AND APPURTENANCES with the following statement: Valve body components shall be constructed of ASTM A536, Grade 65-45-12 cast ductile iron. The valve body end-castings shall be fitted with Class 250-lb ANSI flanges.
2. Remove any reference to Electric Motor-Driven Actuator or Water Operated Hydraulic Actuator. The Mechanical Valve Actuator shall be as stated in Section 40 05 63 METAL-SEATED BALL VALVE AND APPURTENANCES where it is written in paragraph 18.8.13 of paragraph 18.8 – Metal-Seated Ball Valves that ball valves shall be furnished with a worm gear drive and handwheel operator fitted with a gate stem extension of appropriate length as specified in Section 40 05 57.10. See attached photo.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the Signature Page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. TW23-0025N Addendum No. 1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

