

**CITY OF TACOMA**  
**REQUEST FOR QUOTATION**  
**GENERAL TERMS AND CONDITIONS**

**1. Preparation/Submittal of Bids**

A. All information requested of the Bidder/Proposer must be entered in the appropriate space on the form. Failure to do so may disqualify your bid/proposal.

B. All information must be written in ink or typewritten. Mistakes may be crossed out and corrections inserted before submission of your bid/proposal. Corrections shall be initialed in ink by the person signing the bid/proposal.

C. Time of delivery must be stated as the number of calendar days following receipt of the order by the Bidder/Proposer to receipt of the goods or services by the City and may be a determining factor in the award of the contract.

D. All bids/proposals must be signed by an authorized officer or employee of the Bidder/Proposer.

E. The City of Tacoma will not be responsible for any explanation interpretation of the RFB/RFQ/RFP documents, except if made by written addendum.

F. Bids/Proposals must be submitted by or prior to the RFB/RFQ/RFP date and time specified. The RFB/RFQ/RFP number, opening date and Buyer must be noted on the face of the envelope if submitted by mail or in person.

G. Submission of a facsimile bid/proposal in lieu of a mailed bid/proposal is at the option of the Bidder/Proposer unless otherwise stated in the RFB/RFQ/RFP. The City accepts no responsibility for transmission errors if transmitted by fax.

H. All bid/proposal prices must remain firm for acceptance by the City for a period of at least 60 calendar days from the RFB/RFQ/RFP opening date.

**2. Bid/ Proposal Withdrawal:** No bid/proposal can be withdrawn after having been formally opened by a representative from the City Purchasing Office.

**3. Shipping and Delivery:** F.O.B. Point/Freight: All prices quoted shall be F.O.B. destination, freight prepaid and allowed. Failure to meet this requirement may result in your bid/proposal being rejected as non-responsive. Deliveries will be accepted between 9:00 a.m. and 3:30 p.m., at the delivery address shown on the front of the RFB/RFQ/RFP, Monday through Friday (except on legal holidays of the City of Tacoma).

**4. Payment Terms:** Prices will be considered as net 30 if no cash discount is shown. Payment discount periods of twenty (20) calendar days or more will be considered in determining the apparent lowest responsible bid/proposal. Invoices will not be processed for payment nor will the period of the cash discount commence until receipt of a properly completed invoice and until all invoiced items are received and satisfactory performance of the contractor has been attained. If an adjustment in payment is necessary due to damage or dispute, the cash discount period shall commence upon the final approval for payment.

**5. Terms and Conditions:** All terms and conditions of the City of Tacoma Purchase Order form shall apply to contracts resulting from this RFB/RFQ/RFP.

**6. Taxes:**

A. The City of Tacoma is exempt from Federal excise tax.

B. The City of Tacoma is subject to Washington State Sales Tax.

C. Section 6A.30.060 of the Tacoma Municipal Code (TMC) provides that all transactions with the City of Tacoma, wherever consummated, are subject to the City's Business and Occupation Tax. It is the responsibility of the Bidder/Proposer awarded the Contract to register with the City of Tacoma's Finance, Tax and License Division, 733 Market Street, Room 21, Tacoma, WA 98402-3768, 253-591- 5252. The City's Business and Occupation Tax amount shall not be shown separately but shall be included in the unit and/or lump sum prices bid.

D. Do not include Washington State Sales Tax or Federal Excise Tax in the prices quoted. Bidder/Proposer is responsible to determine the correct sales tax rate to be paid and include it in the appropriate blank on the RFB/RFQ/RFP page.

**7. Increase or Decrease in Quantities/Extensions:** The City reserves the right to increase or decrease the quantities of any item under this contract and pay according to the unit price in the RFB/RFQ/RFP. Unless otherwise specified in the solicitation, contracts resulting from this RFB/RFQ/RFP are subject to extension by mutual agreement at the same prices, terms and conditions.

**8. Evaluation of Bids/Awards:**

A. The City reserves the right to: (1) award bids/proposals received based on individual items or groups of items, or on the entire list of items (2) to reject any or all bids/proposals or any part thereof, and if necessary, call for new bids/proposals (3) to waive any informality in the bids/proposals, and (4) to accept the bid/proposal that is the lowest and the best bid/proposal in the interest of the City of Tacoma.

B. The City reserves the right to correct ambiguities and obvious errors in the Bidder/Proposer's proposal. In this regard, if the unit price does not compute to the extended total price, the unit price shall govern.

C. In the evaluation of bids/proposals, the Bidder's/Proposer's experience, delivery time, and responsibility in performing other contracts will be considered. In addition, the bid/proposal evaluation factors set forth in TMC Section 1.06.253 may be considered by the City as well as the tax revenue the City would receive from purchasing item(s) from a supplier or suppliers located inside or outside the boundaries of the City of Tacoma.

**9. Approved Equivalents:**

A. Unless an item is indicated "No Substitute," special brands, when named, are intended to describe the standard of quality, performance or use desired. Equivalent items will be considered by the City, provided that the Bidder/Proposer specifies the brand and model, and provides all descriptive literature, independent test results, product samples, etc., to enable the City to evaluate the proposed "equivalent."

B. The decision of the City as to what items are equivalent shall be final and conclusive. If the City elects to purchase a brand represented by the Bidder/Proposer to be an "equivalent," the City's acceptance of the item will be conditioned on the City's inspection and testing after receipt. If, in the sole judgment of the City, the item is determined not to be an equivalent, the item shall be returned at the Bidder/Proposer's expense and the contract canceled without any liability whatsoever to the City.

C. When a brand name or level of quality is not stated by the Bidder/Proposer, it is understood the offer is exactly as specified. If more than one brand name is specified, Bidder/Proposer must clearly indicate the brand and model/part number being bid/proposed.

**10. Warranties/Guarantee:** Bidder/Proposer warrants that all materials, equipment and/or services provided as a result of the RFB/RFQ/RFP shall be fit for the purpose(s) for which intended, for merchantability, and shall conform to the requirements and specifications of the RFB/RFQ/RFP; all items comply with all applicable safety and health standards established for such products by the Washington Industrial Safety and Health Act (WISHA), RCW Chapter 49.17, the U.S. Occupational Safety and Health Act (OSHA) and/or Consumer Products Safety Act, and all other applicable federal laws or agency rules; all items are properly packaged; and all appropriate instructions or warnings are supplied including any applicable MSDS sheets.

**11. Legal Disputes:** The sole venue of any legal action arising out of the Contract or any bids submitted in response to this RFB/RFQ/RFP shall be in the Pierce County Superior Court for the State of Washington and the interpretation of the terms of the Contract shall be governed by the laws of the State of Washington.

**12. Contract Compliance Forms:** TMC requires Bidder/Proposer's to submit proof and/or documentation of compliance with the City's requirements for equal economic opportunity and solicitation of Historically Underutilized Business subcontractors. If compliance forms are included with this RFB/RFQ/RFP, they must be fully and accurately completed and submitted at time of RFB/RFQ/RFP opening. Failure to do so may result in the bid/proposal being declared non-responsive. For compliance questions contact the City's Contract Compliance Office 747 Market Street, Tacoma, WA 98402, 253-591-5825.

**13. Code of Ethics:** TMC, Chapter 1.46, provides standards for certain unethical conduct by others including bidders and contractors. Violation of the City's code of ethics shall constitute a breach of contract, and will be grounds for termination of this contract.

**14. Prevailing Terms and Conditions:** Bidder/Proposer acknowledges and agrees that the terms and conditions stated herein shall control and prevail over any other conflicting terms and conditions Bidder/Proposer may present in connection with this Contract.



# CITY OF TACOMA

Page 1 of 14

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

### Return Bids By 11:00 AM, 12/07/2020 to:

Debbie Seibert  
D Seibert  
ABN 4th Floor NE  
3628 South 35th Street  
Tacoma WA 98409  
Ph. 253 502 8587  
Fax.253-502-8372

### Material will ship to:

Water Warehouse  
3506 S 35th St  
Tacoma WA 98409

### RFQ Information

Collective Bid #	TW20-0366N
Bid Issue Date	11/30/2020
Vendor Number	109226 WEB VENDOR FOR RFQ

### Vendor Information (vendor to complete)

Firm Name:	
Address:	
City/State/Zip	/ /
Phone/Fax	/
E-Mail	
Contact Name	
Payment Terms	%, days (e.g. 2% 10,N30)
Tacoma Bus. Lic. #	
Taxpayer ID #	

### SIGNATURE OF PERSON AUTHORIZED TO SIGN THIS BID

x \_\_\_\_\_ DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
NAME : \_\_\_\_\_  
TITLE : \_\_\_\_\_

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	<p>E-mail bid to sendbid@cityoftacoma.org . Please include the Collective Bid Number TW20-0366N in the subject line of your e-mail.</p> <p>Bids are subject to the submittal deadline noted in the bid solicitation document. The time of e-mail receipt will be considered as the time of submittal.</p> <p>IT IS ANTICIPATED THAT VENDORS WILL ATTEMPT TO PROVIDE PRICING FOR AS MANY ITEMS AS POSSIBLE.</p> <p>ITEMS MUST BE NEW AND UNUSED.</p> <p>PLEASE CIRCLE OR UNDERLINE THE MODEL/BRAND QUOTED IF MULTIPLE MANUFACTURERS ARE LISTED OR BID MAY BE CONSIDERED NON-RESPONSIVE. DELIVERY DATE WILL DEFAULT TO TWO WEEKS ARO IF VENDOR FAILS TO PROVIDE. IF DELIVERY DATES CAN NOT BE UPHELD, IT IS THE VENDOR'S RESPONSIBILITY TO MAKE CONTACT WITH THE BID ORIGINATOR @ 253 502-8587.</p> <p>BIDS MUST BE SIGNED IN ORDER TO BE A VALID BID.</p>					



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	BID RESULTS ARE POSTED AT <a href="http://www.cityoftacoma.org/government/city_departments/finance/procurement_and_payables_division/purchasing/bid_results/">http://www.cityoftacoma.org/government/city_departments/finance/procurement_and_payables_division/purchasing/bid_results/</a>					



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total															
10	32184	<p><b>YOKE,3/4IN X 21IN,METER,WITH TIEBAR</b></p> <p>YOKE,METER SETTER, 3/4" X 21" H, WITH TIE BAR,FULL PORT ANGLE BALL VALVE INLET WITH PADLOCK WINGS, "KEY" STYLE OPERATING NUT WITH FLOW DIRECTION INDICATOR CAST IN TOP METER SWIVEL NUTS SHALL HAVE A LIP TO SUPPORT THE METER DURING INSTALLATION, DOUBLE PURPOSE UNION ON THE INLET AND OUTLET, MINUS THE DOUBLE PURPOSE NUT, SUPPLIED WITH THREAD PROTECTION. RUBBER GASKETS MUST BE PROVIDED. ALL MATERIALS USED IN THE CONSTRUCTION OF THE METER SETTERS AND YOKES, RESETTERS, INSETTERS AND HORNS SHALL BE NEW AND CONFORM TO THE APPLICABLE SECTIONS OF THE REVISION OF AWWA STANDARD C800.</p> <p>BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.</p> <p>APPROVED: FORD VB73-21W-11-33-FP-LDP-NL MUELLER 3/4X21 B2404 MCDONALD #20-321JXLL JAMES JONES J02BUNUNBVMC21</p> <p>NO SUBSTITUTIONS</p> <table><tr><td>Material #</td><td>Manf Part#</td><td>Manufacturer Name</td></tr><tr><td>10006730</td><td>720-321JXLL</td><td>A.Y. MCDONALD</td></tr><tr><td>10007063</td><td>J02BUNUNBVMC21</td><td>JAMES JONES</td></tr><tr><td>10006422</td><td>VB73-21W-11-33-FP-LDP-NL</td><td>FORD METER BOX CO</td></tr><tr><td>10005980</td><td>3/4X21 B2404N</td><td>MUELLER</td></tr></table>	Material #	Manf Part#	Manufacturer Name	10006730	720-321JXLL	A.Y. MCDONALD	10007063	J02BUNUNBVMC21	JAMES JONES	10006422	VB73-21W-11-33-FP-LDP-NL	FORD METER BOX CO	10005980	3/4X21 B2404N	MUELLER		100	EA		
Material #	Manf Part#	Manufacturer Name																				
10006730	720-321JXLL	A.Y. MCDONALD																				
10007063	J02BUNUNBVMC21	JAMES JONES																				
10006422	VB73-21W-11-33-FP-LDP-NL	FORD METER BOX CO																				
10005980	3/4X21 B2404N	MUELLER																				



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
20	30763	<b>CLAMP,4IN X 2IN,SERVICE,PIPE THREAD</b> CLAMP,4" X 2"SERVICE, IRON PIPE THREAD OUTLET. DUCTILE IRON BODY (PAINTED), AND DOUBLE(TWO) STAINLESS STEEL STRAPS,(4EA. 5/8 STUDS). STAINLESS STEEL 1-1/16" HEX NUTS AND WASHERS. RANGE 4.50"-4.80", TO BE PERMANENTLY INDICATED ON THE BODY OF THE CLAMP. PRODUCT ORDERING CODE CHANGES WILL BE CAUSE FOR RE-EVALUATION OF THE PRODUCT AND RE-APPROVAL BY THE WATER DIVISION.  NOT ACCEPTABLE: JCM ROBAR SMITH-BLAIR 317  Material #      Manf Part#      Manufacturer Name 10011155      202S-4.80X2      ROMAC 10011154      FSD-202-480-IP7      FORD METER BOX CO		8	EA		
30	30804	<b>ADAPTER,8IN X 24IN,FLNG X FLNG,DI</b> ADAPTER, FLANGE X FLANGE, 8INCH INSIDE DIAMETER X 24 INCH LAYING LENGTH, DUCTILE IRON, MORTAR LINED. CAST CLASS 52 OR FABRICATED USING SPECIAL CLASS 53 DI PIPE WITH THREADED (SOLID BACK) DUCTILE IRON FLANGES(CLASS 125). MUST COMPLY WITH THE LATEST REVISIONS OF AWWA STANDARDS; C-104, C-110, C-115, C-150, C-151 AND C-153.		6	EA		
40	30816	<b>ADAPTER,8IN X 24IN,FLNG X MJ,DI</b> ADAPTER, FLANGE X MECHANICAL JOINT, 8IN INSIDE DIAMETER X 24IN LAYING LENGTH, DUCTILE IRON, CAST CLASS 52 OR FABRICATED USING CLASS 53 DI PIPE WITH THREADED FLANGES (150# DRILLING). MUST COMPLY WITH THE LATEST REVISIONS OF AWWA STANDARDS C-104, C-110, C-115, AND C-153. NO ACCESSORIES.		4	EA		



# CITY OF TACOMA

Page 5 of 14

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
50	31524	<b>REDUCER,4IN FLNG X 3IN FNLG,DI</b> REDUCER, 4IN FLANGE X 3IN FLANGE, DUCTILE IRON, CEMENT MORTAR LINED. MUST COMPLY WITH THE LATEST REVISIONS OF THE ANSI/AWWA C-110, C-104 AND C-153.  NO ACCESSORIES.  Material provided under this specification must be manufactured within two years of the date of the purchase order unless prior approval is obtained from Tacoma Water.		6	EA		
60	32161	<b>TEE,2IN X 2IN X 3/4IN,BRASS</b> TEE, BRASS, 2IN X 2IN X 3/4IN.  "MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"		12	EA		
70	32178	<b>UNION,BRASS,GROUND JOINT,1"</b> UNION, BRASS, GROUND JOINT, 1IN.  BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372 AND IDENTIFIED AS COMPLIANT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.		4	EA		



# CITY OF TACOMA

Page 6 of 14

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
80	32019	<b>FITTING,1IN,COMPRESSION,YOKE TO COMP</b> COMPRESSION FITTING, MULTI PURPOSE YOKE THREAD X COMPRESSION, FOR CTS O.D. TUBING, SIZE 1 INCH.  BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.  APPROVED: FORD, A.Y. MCDONALD 76100Q, MUELLER H 14227N		20	EA		
90	32132	<b>NIPPLE,2IN X 8IN,RED BRASS</b> NIPPLE,RED BRASS, 2IN X 8IN.  MUST MEET ASTM B43 FOR SEAMLESS RED BRASS PIPE AND NSF 372 FOR LEAD CONTENT.		20	EA		
100	32133	<b>NIPPLE,2IN X 14IN,RED BRASS</b> NIPPLE, 2IN X 14IN,RED BRASS.  MUST MEET ASTM B43 FOR SEAMLESS RED BRASS PIPE AND NSF 372 FOR LEAD CONTENT.		50	EA		



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
110	32192	<p><b>YOKE,2IN X 18IN X 17IN,METER</b></p> <p>YOKE, METER, 2 INCH X 18 INCH X 17 INCH, 2 INCH COPPER METER SETTER WITH FEMALE IRON PIPE, HORIZONTAL INLET AND OUTLET, FULL PORT ANGLE METER BALL VALVE INLET AND OUTLET AT THE METER, HIGH BY-PASS. MINIMUM 1 IN COPPER TUBE WITH LOCKING BALL VALVE. CENTER LINE OF HIGH BY-PASS TO BE OFF SET 6-1/2 TO 7-1/2 INCHES FROM THE CENTER LINE OF THE INLET AND OUTLET RISERS, AND 5 TO 8-1/2 INCHES BELOW THE CENTER LINE OF METER FLANGES. ALL BALL VALVES MUST HAVE PAD LOCK WINGS. ALL MATERIALS USED IN THE CONSTRUCTION OF THE SETTERS SHALL CONFORM TO THE APPLICABLE SECTIONS OF THE LATEST REVISION OF AWWA STANDARD C-800.</p> <p>BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.</p>		40	EA		
Material #		Manf Part#    Manufacturer Name					
10007067		J02FFIPFIPBVBV18    JAMES JONES					
10005987		106B2423----06N    MUELLER					
10006872		720R718JJFF775    A.Y. MCDONALD					
10006871		VBB77-18HB-11-77NL    FORD METER BOX CO					





# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
120	33702	<b>DIAPHRAGM,PILOT VALVE,CLA-VAL</b> DIAPHRAGM, PILOT VALVE, CLA-VAL, CRD, CRA, AND CDHS-2, P/N C6936D.  Material #      Manf Part#      Manufacturer Name 33702              C6936D              CLA-VAL		80	EA		
130	35516	<b>CLAMP,20IN X 2IN CC,SVC</b> CLAMP,SERVICE,20" X 2" CC(AWWA) THREAD OUTLET. DUCTILE IRON BODY (PAINTED), AND DOUBLE(TWO) STAINLESS STEEL STRAPS,(4EA. 5/8 STUDS). STAINLESS STEEL 1-1/16" HEX NUTS AND WASHERS. RANGE 21.60"-22.06", TO BE PERMANENTLY INDICATED ON THE BODY OF THE CLAMP. PRODUCT ORDERING CODE AND RANGE CHANGES WILL BE CAUSE FOR RE-EVALUATION OF THE PRODUCT AND RE-APPROVAL BY THE WATER DIVISION.  Material #      Manf Part#      Manufacturer Name 10004281          202S              ROMAC 10004282          FSD-202          FORD METER BOX CO		1	EA		
140	33813	<b>VALVE,3/8IN,PILOT,CRA,15 TO 75 PSI</b> VALVE, PILOT, CRA, 3/8", 15 TO 75 PSI, 1/4"SEAT CLA-VAL NUMBER 7974403#  Material #      Manf Part#      Manufacturer Name 33813              7974403          CLA-VAL		2	EA		



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
150	31457	<b>PLUG,4IN,PIPE,DI,MECHANICAL JOINT</b> PLUG, PIPE, 4IN, DUCTILE IRON, MECHANICAL JOINT, WITHOUT BOLTS OR GASKETS. FITTINGS SHALL CONFORM TO THE LATEST ANSI/-AWWA C110-82 AND ANSI/AWWA C104/A21.4-85  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST BE MANUFACTURED WITHIN TWO YEARS OF THE DATE OF THE PURCHASE ORDER UNLESS PRIOR APPROVAL IS OBTAINED FROM TACOMA WATER.#		10	EA		
160	31977	<b>STOP,5/8X3/4,WATER,YOKE,LOCK ON/OFF</b> STOP, WATER, YOKE, 5/8" X 3/4", LOCK ON/OFF  BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.  APPROVED: FORD NO. BA13-232WW 5/8" AY MCDONALD NO. 74644 BWW 3/4". MUELLER B24265N		200	EA		
170	30812	<b>ADAPTER,4IN X 24IN,FLNG X MJ,DI</b> ADAPTER, FLANGE AND MECHANICAL JOINT, 4" ID X 24" LAYLING LENGTH. DUCTILE IRON. CAST CLASS 52 OR FABRICATED USING CLASS 53 DI PIPE WITH THREADED FLANGES (150# DRILLING). MUST COMPLY WITH THE LATEST REVISIONS OF AWWA STANDARDS C-104, C-110, C-115, AND C-153. NO ACCESSORIES.		30	EA		



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
180	<b>31814</b>  <b>VALVE,3/4IN IPT,CHECK,SWING,BRONZE,HORIZ</b> VALVE CHECK SWING BRONZE 3/4IN NPTxNPT, WYE PATTERN BODY, CLASS 150, BRASS/BRONZE SEAT AND DISC, SCREWED BRONZE CAP, STAINLESS STEEL HINGE PIN. MUST MEET NSF/ANSI 61-8, ANNEX G AND NSF/ANSI 372 LEAD FREE  APPROVED: APOLLO 3/4IN PART NUMBER 61YLF-194-01  OR APPROVED EQUAL  Material #      Manf Part#      Manufacturer Name 10010610      61YLF-194-01      APOLLO		25	EA		
190	<b>31953</b>  <b>BUSHING,1IN X 3/4IN NPT ,BRASS</b> BUSHING, BRASS, 1IN X 3/4IN NPT  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT		40	EA		
200	<b>32030</b>  <b>FITTING,1IN X 3/4IN,COMP X MIPT</b> FITTING, 1 INCH X 3/4 INCH, COMPRESSION X MALE IRON PIPE THREAD. FOR OUTSIDE DIAMETER CTS TUBING.  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT  * * * NO SUBSTITUTIONS * * *   Material #      Manf Part#      Manufacturer Name 10006964      C84-34-QNL      FORD METER BOX CO 10006963      74753Q      A.Y. MCDONALD		200	EA		



# CITY OF TACOMA

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
	10006962	H-15428N MUELLER					
210	32061	<b>ELL,3/4IN,CAST BRASS,90 DEG,FIPT X FIPT</b> ELL, 3/4IN, CAST BRASS, 90 DEGREE, FIPT X FIPT.  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"		80	EA		
220	32062	<b>ELL,1IN,CAST BRASS,90 DEG,FIPT X FIPT</b> ELL, 1 INCH, CAST BRASS, 90 DEGREE, FIPT X FIPT.  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"		25	EA		
230	33686	<b>DISK &amp; DIAPHRAGM,1-1/4IN,REPAIR,ASSY</b> ASSEMBLY, REPAIR, DISC & DIAPHRAGM, NUMBER C2522F CLA VALVE 1 1/4 TO 1 1/2 VALVES#  Material #      Manf Part#      Manufacturer Name 33686          C2522F          CLA-VAL		5	EA		
240	40068	<b>ADAPTER,4IN X 12IN,FLNG X FLNG,DI</b> ADAPTER, FLANGE X FLANGE, 4 INCH INSIDE DIAMETER X 12 INCH LAYING LENGTH, DUCTILE IRON, MORTAR LINED, CAST CLASS 52 OR FABRICATED USING SPECIAL CLASS 53 DI PIPE WITH THREADED (SOLID BACK) DUCTILE IRON FLANGES(CLASS 125). MUST COMPLY WITH THE LATEST REVISIONS OF AWWA STANDARDS; C-104, C-110, C-115, C-150, AND C-151.  Material provided under this specification must be manufactured within two years of the date of the purchase order unless prior approval is obtained from Tacoma Water.		12	EA		



# CITY OF TACOMA

Page 12 of 14

**THIS IS NOT AN ORDER**  
**All prices quoted shall be F.O.B.**  
**Destination, Freight Prepaid and Allowed**

All responses & inquiries must be  
plainly marked with this

## REQUEST FOR QUOTATION 6000049951

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
250	32005	<b>COUPLING,2IN,CAST BRONZE</b> COUPLING, CAST BRONZE, 2 INCH.  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"		30	EA		
260	32026	<b>FITTING,2IN,COMPRESSION,COMP X COMP</b> COMPRESSION FITTING, 2 INCH, COMPRESSION X COMPRESSION, FOR CTS O.D. TUBING.  BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.  Material #      Manf Part#      Manufacturer Name 10006967      H-15403N      MUELLER 10006969      C44-77-QNL      FORD METER BOX CO 10006968      74758Q      A.Y. MCDONALD		20	EA		
270	32076	<b>ELL,2IN,STREET,CAST BRONZE,90 DEG</b> ELL, 2 INCH, STREET, 90 DEGREE, CAST BRONZE  MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372		40	EA		
280	32130	<b>NIPPLE,2IN X 4IN,RED BRASS</b> NIPPLE, RED BRASS, 2 INCH X 4 INCH.  RED BRASS, MUST MEET ASTM B43 FOR SEAMLESS RED BRASS PIPE AND NSF 372 FOR LEAD CONTENT		30	EA		

<b>Net Value</b>	<b>\$</b>
<b>Plus Tax at</b> <b>_____ %</b>	<b>\$</b>
<b>Total Amount</b>	<b>\$</b>