



**CITY OF TACOMA**  
**Tacoma Water**

**ADDENDUM NO. 02**

**DATE:** July 28, 2021

**REVISIONS TO:**  
**Specification No. TW21-0503N**  
**McMurray Pump Station Demolition**

**NOTICE TO ALL BIDDERS:**

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

**REVISIONS TO THE SUBMITTAL DEADLINE:**

The submittal deadline remains the same.

**REVISIONS TO THE TECHNICAL REQUIREMENTS:**

Section Technical Provisions 20.11 Special Contractor Requirements – Add Line Item 10.:

10. Contractor shall have Fire Suppression Water Trailer and hose onsite during all operations conducted in the process of all demolition, excavation and road building. The water tank shall have a capacity of a minimum of 500 gallons and include a self-contained engine, pump and hose.

Section Technical Provisions 20.11 Special Contractor Requirements – Add Line Item 11.:

11. Contractor shall have Hazardous Material Spill Kit onsite during all operations conducted in the process of all demolition, excavation and road building. The spill kit shall be OSHA certified for motor and hydraulic oil, gasoline, diesel and solvents.

**REVISIONS TO THE SPECIAL PROVISIONS:**

Section Special Provisions -19.12 Permits – Add Line Item: The Contractor will be responsible to submit notification to the: Puget Sound Clean Air Agency for the asbestos found within the pump station. The Hazardous Material Survey (ERM-McMurray Station RBMS Summary Memo 2.12.21 (Regulated Materials Survey Analysis Report) required by the agency is included in Appendix “A” at the end of the specifications. Contractor will have to wait 10 days prior to building demolition. Mobilization, clearing and road construction work is allowed to go forward unless otherwise indicated by the Puget Sound Clean Air Agency permit. Note: A fee may be required. Any such fees will be the responsibility of the contractor.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Specification No. TW21-0503N Addendum No.2 The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Ralph Eaton, Tacoma Water