



CITY OF TACOMA
Public Works Engineering

ADDENDUM NO. 2

DATE: 7/30/2020

REVISIONS TO:

Request for Bids Specification No. PW19-0390F
Convention Center Guard House

NOTICE TO ALL Bidders:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline has been changed to 11:00 a.m., Pacific Time, Tuesday, August 11, 2020.

RESPONSES TO QUESTIONS:

Question #1:

EIC Requirement – There is not enough subcontracting trades or dollar value in this project to meet the EIC requirements. What other options are available?

Response #1

Included in the EIC Requirements is an Application for Waiver of EIC Requirements with instructions for completing the form.

Question #2:

Section 133423 – Paragraph 2.03 – GWB walls, the manufacturer only does galvanized steel painted walls, will this be acceptable?

Response #2

If GWB Walls are not available from the prefab manufacturer, galvanized steel painted walls will be acceptable, except for the wall where new electrical/security panels are to be installed by the GC.

Question #3:

Section 133423 – Paragraph 2.06 – Please provide information on what is existing so that we can determine what would be compatible.

Response #3:

Information is not available, GC to confirm on site.

Question #4:

Section 133423 – Paragraph 2.10 D – The building manufacturer does not install boxes as specified, can they be surface mounted?

Response #4:

Owner will work with Manufacturers restrictions if this option is not available.

Question #5:

Section 133423 – Paragraph 2.10 F – Split system does not require louvers shown on the elevation. Is the louver required?

Response #5

Louvers are not required if not needed for Mechanical system.

Question #6:

Section 211000 – Is Fire Suppression required?

Response #6

Yes, the booth needs to be fully sprinklered.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the Signature Page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PW19-0390F Addendum No. 2. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

Jon Kulju/PW