



CITY OF TACOMA
Public Works Engineering

ADDENDUM NO. 3

DATE: 8/4/2020

REVISIONS TO:

**Request for Bids Specification No. PW19-0390F
Convention Center Guard House**

NOTICE TO ALL Bidders:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

RESPONSES TO QUESTIONS:

Question #1:

Is the new guard shack a single point connection? Is the shack already assembled with receptacles, lighting, switches, etc and all we need to run is power to the provided shack panel.

Response #1:

The guard house is a single point connection with modifications for the low voltage systems.

Question #2:

Do we need to provide a fiber panel? Do we need to provide a patch panel for the data?

Response #2:

The contractor will install patch panels for 6 strand fiber and (6) cat 6A cables from the main telecom room to the guard house as indicated and specified.

Question #3:

Is the Parking Deck post tensioned?

Response #3:

The parking deck is post tensioned.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the Signature Page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PW19-0390F Addendum No. 3. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

Jon Kulju/PW